

AS 1851-2012 Routine service frequencies and tolerances



| | | AS 1851-2012 Section | | | | | | | | | | | | | |
|------------------------|-----------|----------------------|-----------------|--------------------|--------------------|------------------|----------------------|---------------------|----------------------|------------------------------|---------------------|-----------------------|---------------------------|--------------------------|------------------|
| Frequency | | 2 Fire sprinklers | 3 Fire pumps | 4 Fire hydrants | 5 Storage tanks | 6 Fire alarms | 7 Special hazards | 8 Lay flat hoses | 9 Fire hose reels | 10 Portable extinguishers | 11 Fire blankets | 12 Passive & smoke | 13 Mechanical services | 14 Emergency planning | Tolerances + / - |
| Up to annual servicing | Monthly | • | • | • | • | • | • | | | | | | • | | 5 Working days |
| | 3 Monthly | | | | | | | | | | | • | • | | 10 Working days |
| | 6 Monthly | • | • | • | • | • | • | | • | • | • | • | • | • | 1 Month |
| | Yearly | • | • | • | • | • | • | • | • | • | | • | • | • | 2 Months |
| Post annual servicing | 2 Yearly | | •* | | | | | | | | | | | | 2 Months |
| | 3 Yearly | | | | | | | | | •** | | | | | 3 Months |
| | 5 Yearly | • | • | • | | • | | | | • | | | • | | 3 Months |
| | 10 Yearly | • | | | • | | | | | | | | • | | 6 Months |
| | 25 Yearly | • | | | | | | | | | | | | | 6 Months |
| | 30 Yearly | • | | | | | | | | | | | | | 6 Months |

Note: The tolerances referenced are not meant to necessitate any extra maintenance activities.

* As per table 3.4.3, item 3.5.

** As per clause 10.2.3.

For more information on preparing for AS 1851-2012

Email technical@fpaa.com.au or visit fpaa.com.au